


THIS DRAWING IS THE PROPERTY OF INDUSTRIAL COMBUSTION  
IT IS SUBJECT TO CHANGE WITHOUT NOTICE, AND IS NOT TO BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE COMPANY.

NOTE: EACH MOTOR AND HEATER IS TO BE FUSED SEPARATELY (BY OTHERS).  
SEE CONTACTOR/STARTER FOR ANY SPECIFIC REQUIREMENTS.



WARNING: THESE DRAWINGS ARE TO BE USED ONLY IN CONNECTION WITH EQUIPMENT COMPLYING IN ALL RESPECTS WITH THE ORIGINAL MANUFACTURER'S SPECIFICATIONS. INSTALLER SHOULD INSPECT EQUIPMENT AND ASCERTAIN COMPLIANCE WITH ORIGINAL MANUFACTURER'S SPECIFICATIONS BEFORE USING THESE DRAWINGS. DO NOT USE THESE DRAWINGS IF THE EQUIPMENT HAS BEEN MODIFIED, SUCH USE MAY CAUSE EQUIPMENT FAILURE OR MALFUNCTION WHICH MAY RESULT IN ELECTRICAL SHOCK OR BURNS OR OTHER SEVERE PERSONAL INJURY AND PROPERTY DAMAGE. INDUSTRIAL COMBUSTION DISCLAIMS ANY AND ALL LIABILITY FOR ANY INJURY OR DAMAGE, WHETHER DIRECT, INDIRECT, INCIDENTAL OR CONSEQUENTIAL, RESULTING FROM THE USE OF THESE DRAWINGS IN CONNECTION WITH EQUIPMENT WHICH DOES NOT COMPLY IN ALL RESPECTS WITH THE MANUFACTURER'S ORIGINAL SPECIFICATIONS.

REVISIONS	DATE	BY	DESCRIPTION
1	10/05/82	MS	REVISED
2	10/22/89	TD	NEW FORMAT
3	09/27/86	DP	AUTO./MAN. START

WIRE COLOR	SYMBOL	WIRE ALL CIRCUITS N.E.C. CLASS 1; NOT RESPONSIBLE FOR WIRING NOT INSTALLED AT THE FACTORY.
YELLOW	Y	
ORANGE	O	
RED	R	
BLUE	BL	
WHITE	W	
BLACK	B	

SCALE	DATE	OPTIONAL EQUIPMENT
12/27/94	12/27/94	NOT FURNISHED UNLESS SPECIFIED IN CONTRACT.

MODEL	DATE	SCALE
MMG-28,30,34,42,54,63	12/27/94	1/2" = 1'-0"

MANUFACTURER	MODEL	DATE
INDUSTRIAL COMBUSTION	MONROE, WIS.	12/27/94

SIZE	DRWG. NO.
D	731 06557

REVISIONS	DATE	BY	DESCRIPTION
1	12/27/94	MS	REVISED

WIRE COLOR	SYMBOL	WIRE ALL CIRCUITS N.E.C. CLASS 1; NOT RESPONSIBLE FOR WIRING NOT INSTALLED AT THE FACTORY.
YELLOW	Y	
ORANGE	O	
RED	R	
BLUE	BL	
WHITE	W	
BLACK	B	

SCALE	DATE	OPTIONAL EQUIPMENT
12/27/94	12/27/94	NOT FURNISHED UNLESS SPECIFIED IN CONTRACT.

MANUFACTURER	MODEL	DATE
INDUSTRIAL COMBUSTION	MONROE, WIS.	12/27/94

BROOKLYN UNION GAS	
B	MANUAL RESET EXCESS LIMIT CUT OUT SWITCH (BY OTHERS)
C	
D	MANUAL RESET THERMAL SPILL SWITCH FOR BAROMETRIC DRAFT REGULATOR
E	HIGH FIRE INTERLOCK SWITCH REED FOR BROOKLYN UNION GAS MOUNTED ON BURNER AIR SHUTTER
F	WHEN NO P.O.C. IS USED JUMPER BURNER PANEL TERMINALS 10 AND 11.
G	
H	OUTDOOR TEMPERATURE CONTROL FOR B.U.G. TO BE DIGI-SPAN MODEL SPC-100-T RANGE (-30 DEG. TO +100 DEG. F.)

THIS DRWG. REPLACES D-731-05018-03 12/27/94